

CONFIDENTIAL

25X1A

Nine Point Temperature Readings in Room - 20 August 1971

Position	<u>1155 hrs.</u>	<u>1225 hrs.</u>	<u>1245 Hrs.</u>	<u>1534 hrs.</u>
1	73.1	73.4	73.6	73.0
2	73.4	73.6	73.8	73.2
3	73.4	73.6	73.2	72.3
4	72.9	73.4	73.4	72.6
5	72.7	73.1	73.1	71.7
6	75.5	74.8	75.0	74.0
7	73.6	73.7	74.0	72.4
8	73.8	73.8	73.6	72.7
9	75.4	75.2	75.2	75.0
Chilled Water	In		45°	44.5°
	Out		55°	54.5°

Declass Review by NIMA/DOD

CONFIDENTIAL